

ADDENDUM NO. 1
WATER SYSTEM IMPROVEMENTS
CONTRACT 16-01 – PITTS GAP ROAD/
HENDON ROAD AREA WATER LINE EXTENSION
CITY OF DAYTON, TENNESSEE
JRWCO JOB NO. 4624

Date of Addendum: March 18, 2016
Bid Opening: March 24, 2016, 2:00 P.M. Local Time

1. Prequalified Bidders:

The following contractors are prequalified to bid on this contract:

Angel Construction
195 Rocking A Farm Lane
Pikeville, TN 37367
Phone: 423-881-3871
Fax: 423-881-3881

Knoxville Excavating, LLC
6326 Maynardville Pike
Knoxville, TN 37918
Phones: 865-689-4370
Fax: 865-687-7618

Meeks Construction, LLC
150 Meeks Mtn. Lane
Sparta, TN
Phone: 931-738-6234
Fax: 931-738-6234

Morgan Contracting, Inc.
916 Katherine Avenue
Knoxville, TN 37921
Phone: 865-249-8640
Fax: 866-249-8651

2. Pre-Bid Meeting Attendance Sheet:


See the attached attendance sheet from the Pre-Bid Meeting.

3. Detailed Specifications, Page DS 4-16:

Modify the second paragraph as follows:

“The pumps shall be a Goulds model number **10SV4GB30**, five HP, 230 volt three phase, capable of producing 60 gallons per minute at 125’ TDH. The pumps shall be equipped with an Aquavar Controller model number **CPC20311**, five HP, **three phase**. The pumps shall also be equipped with a pressure switch on the suction side to shut off the pump if the suction pressure falls below 10 psi. A pressure switch on the discharge side shall interface with the control panel to start the pump when discharge pressure reaches 40 psi and stop the pump when the discharge pressure reaches 80 psi. Pressure switches shall be Square D model number 90137HG39 which is Dayton’s standard. The pump piping shall be 2-inch flange type and the electrical hookups shall be quick disconnect for quick replacement.”

J. R. WAUFORD & COMPANY,
CONSULTING ENGINEERS, INC.

A handwritten signature in black ink, reading "Scott B. Carroll", written over a horizontal line.

Scott B. Carroll, P.E.

Tennessee License No. 116799

Sign in Sheet – Pre-Bid Conference

WATER SYSTEM IMPROVEMENTS
CONTRACT NO. 16-01
PITTS GAP/HENDON ROAD AREA
WATER LINE EXTENSION
DAYTON, TENNESSEE
JRWCO JOB NO. 4624

MANDATORY PRE-BID CONFERENCE:
THURSDAY, MARCH 17, 2016, 10:00 A.M. LOCAL TIME
BID OPENING: THURSDAY, MARCH 24, 2016, 2:00 P.M. LOCAL TIME

| Name | Organization | Email or Phone |
|------------------|----------------------------|---|
| CRAIG CARTWRIGHT | KNOXVILLE EXCAVATING | CBYRONC@COMCAST.NET 865-689-4370 |
| Ryan Nelson | SBW Constructors | rnelson@sbwconstructors.com 423-400-7330 |
| TRACEY GREEN | MCI | tgreen@morganl.com 423-519-2325 |
| Greg Daveport | JRWCO | gregde@jrwanford.com |
| SCOTT CARROLL | JRWCO | scottc@jrwanford.com |
| Brien Mullins | Curtis Excavating | brienmullins45@yahoo.com |
| BRIAN HOLLAND | ANGEL CONST | PATSY.ANGELBASE@YAHOO.COM 931-738-6231 |
| Loni Meeks | G. Meeks Construction, LLC | Meeks@blomard.net |
| Mike Patrick | City of Dayton Water | pmph20@bellsouth.net |
| | | |
| | | |
| | | |
| | | |